

Memo

To: City Council

From: Gary Hartwell

CC: Henry Hill

Date: February 5, 2010

Re: Monthly Report for January, 2010

We recorded 2.5 inches of rainfall in January and used 378.9 million gallons of water for the month. Our average usage was 12.2 million gallons per day (mgd) or about 113 gallons per person per day (gpcd). Our daily water usage ranged from a minimum of 8.0 mgd (74 gpcd) on January 7 to a maximum of 16.8 mgd (155 gpcd) on January 2. The January bacteriological and disinfectant by-product samples all tested negative for contamination. All of our chlorine samples tested within the normal limits for water quality.

We installed 77 water meters in January and we televised 94 private service lines for new homes.

We inspected 1,617 fire hydrants and 119 manholes for proper operation. We repaired 22 sidewalks and installed 212 traffic signs.

We used about 21,000 gallons of unleaded fuel and about 5,240 gallons of diesel fuel in the month of January.

We collected about 2,740 residential tons and about 2,750 tons of commercial solid waste in December. Curbside recycling was about 1,120 tons in December.